



SEÇÕES DOS CONDUTORES NEUTRO E DE PROTEÇÃO			
NEUTRO		PROTEÇÃO	
SEÇÃO DO CONDUTOR FASE	SEÇÃO MÍNIMA DO CONDUTOR NEUTRO	SEÇÃO DO CONDUTOR FASE	SEÇÃO MÍNIMA DO CONDUTOR DE PROTEÇÃO
$S \leq 25$ (mm ²)	S (mm ²)	$1,5$ (mm ²)	$1,5$ (mm ²)
35	25	2,5	2,5
50	25	4	4
70	35	6	6
95	50	10	10
120	70	16,25 e 35	16
150	70	50	25
185	95	70	35
240	120	95	50
300	150	120	70
400	185	150 e 185	95
500	240	240	120
630	300	300	150

[illegible]